

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602736
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 9:25 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **University Park**

Test Site: **University Park**
Hyattsville, MD 20782

Test Report: Radon in Air Test Results**Samples for EMSL Kit 142021**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239736	Main Office	1.5	3/18/2016	3/21/2016	70	50	Customer
381602736-0001			1:45:00 PM	6:00:00 AM			

Sample Notes:

Samples for EMSL Kit 142108

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239709	Room A3	0.9	3/18/2016	3/21/2016	70	50	Customer
381602736-0002			1:50:00 PM	6:05:00 AM			

Sample Notes:

238181	Room A3	0.1	3/18/2016	3/21/2016	70	50	Duplicate
381602736-0003			1:50:00 PM	6:05:00 AM			

Sample Notes:

Duplicate RPD = 160%

Samples for EMSL Kit 142109

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239744	Room A1	1.5	3/18/2016	3/21/2016	70	50	Customer
381602736-0004			1:55:00 PM	6:08:00 AM			

Sample Notes:

Samples for EMSL Kit 142003

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239726	Room B1	0.4	3/18/2016	3/21/2016	70	50	Customer
381602736-0005			1:58:00 PM	6:12:00 AM			

Sample Notes:

Samples for EMSL Kit 141996

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240656	Science Room C2	1.2	3/18/2016	3/21/2016	70	50	Customer
381602736-0006			2:02:00 PM	6:14:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381602736

CustomerID: PGCS62

CustomerPO:

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 9:25 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **University Park**

Test Site: **University Park**
Hyattsville, MD 20782

Test Report: Radon in Air Test Results**Samples for EMSL Kit 142020**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240612	Room B3	0.2	3/18/2016	3/21/2016	70	50	Customer
381602736-0007			2:05:00 PM	6:18:00 AM			

Sample Notes:**Samples for EMSL Kit 142024**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240603	Room E1	1.9	3/18/2016	3/21/2016	70	50	Customer
381602736-0008			2:08:00 PM	6:20:00 AM			

Sample Notes:**Samples for EMSL Kit 141975**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240738	Media Center		3/18/2016	3/21/2016	70	50	Customer
381602736-0009			2:10:00 PM	6:22:00 AM			

Sample Notes: Not Analyzed
 Device received open; unable to analyze.

237805	Media Center	0.1	3/18/2016	3/21/2016	70	50	Blank
381602736-0010			2:10:00 PM	6:22:00 AM			

Sample Notes:**Samples for EMSL Kit 142028**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240604	Room E3	2.1	3/18/2016	3/21/2016	70	50	Customer
381602736-0011			2:13:00 PM	6:24:00 AM			

Sample Notes:

238174	Room E3	0.1	3/18/2016	3/21/2016	70	50	Duplicate
381602736-0012			2:13:00 PM	6:24:00 AM			

Sample Notes:**Duplicate RPD = 181.8%**

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602736
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/24/16 9:25 AM
 Analysis Date: 3/25/2016
 Collected: 3/18/2016

Project: **University Park**

Test Site: **University Park**
Hyattsville, MD 20782

Test Report: Radon in Air Test Results**Samples for EMSL Kit 142027**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240611	Music Room	0.3	3/18/2016	3/21/2016	70	50	Customer
381602736-0013			2:16:00 PM	6:30:00 AM			

Sample Notes:

Samples for EMSL Kit 142112

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239680	Mrs. Tyler	1.7	3/18/2016	3/21/2016	70	50	Customer
381602736-0014			2:20:00 PM	6:35:00 AM			

Sample Notes:

240521	Mrs. Tyler	0.1	3/18/2016	3/21/2016	70	50	Duplicate
381602736-0015			2:20:00 PM	6:35:00 AM			

Sample Notes:

Duplicate RPD = 177.8%

Samples for EMSL Kit 142110

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239750	Mrs. Duffy	1.7	3/18/2016	3/21/2016	70	50	Customer
381602736-0016			2:23:00 PM	6:36:00 AM			

Sample Notes:

Samples for EMSL Kit 142026

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240081	Mrs. Barcarse	1.5	3/18/2016	3/21/2016	70	50	Customer
381602736-0017			2:30:00 PM	6:40:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381602736
CustomerID: PGCS62
CustomerPO:
ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
Fax: (301) 952-0346
Received: 03/24/16 9:25 AM
Analysis Date: 3/25/2016
Collected: 3/18/2016

Project: **University Park**

Test Site: **University Park**
Hyattsville, MD 20782

Test Report: Radon in Air Test Results

Samples for EMSL Kit 142022

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
240675 381602736-0018	Mrs. Coon	3.7	3/18/2016 2:35:00 PM	3/21/2016 6:45:00 AM	70	50	Customer
Sample Notes:							
239815 381602736-0019	Mrs. Coon	0.1	3/18/2016 2:35:00 PM	3/21/2016 6:45:00 AM	70	50	Duplicate
Sample Notes:							

Duplicate RPD = 189.5%

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information. All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Laura Freeman (18)

Laura Freeman, Interim Laboratory Manager &
Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Initial report from 04/01/2016 08:32:39

Please visit www.radontestinglab.com