



Windjammer Environmental LLC
6710 Oxon Hill Road
Suite 210
Oxon Hill, MD 20745
(888) 270-8387
info@wjenviro.com

June 6, 2019

Alex Baylor
Environmental Specialist
PGCPS Environmental Safety Office
13306 Old Marlboro Pike
Upper Marlboro, MD 20772
Alex.baylor@pgcps.org

Re: IAQ and Mold Assessment Report
Prince George's County Public Schools
Friendly High School

Dear Mr. Baylor,

Windjammer Environmental LLC (Windjammer) was contracted to conduct a visual assessment, measure indoor air quality (IAQ) parameters and sample for mold in a limited number of areas at the Friendly High School located at 10000 Allentown Road, Fort Washington, MD 20744. This assessment is intended to check on effectiveness of operations activities that are focused on preventing conditions that can lead to the development of an environment which is historically associated with an increase in reports of poor IAQ. This assessment was conducted by Certified Industrial Hygienists (CIHs) Damien Hammond and Katherine Dietrich on May 25, 2019.

This assessment included:

- Measurement of temperature, relative humidity, carbon dioxide (CO₂) and carbon monoxide (CO)
- Collection of nonviable airborne mold samples; and
- Visual assessment of select areas.

Methods

A TSI IAQ-Calc Model 7545 was used to measure temperature, relative humidity, carbon dioxide (CO₂) and carbon monoxide (CO).

Air samples for non-viable airborne fungi were collected on Air-O-Cell cassettes using a Zefon Bio-Pump Plus portable sampler calibrated to collect 15 liters of air per minute (lpm). The sampling period for the all samples was five minutes.

Direct read instrumentation used were calibrated in accordance with the manufacturer's specifications prior to the start of this assessment.

All samples collected were hand delivered to EMSL of Beltsville, MD and analyzed by EMSL of Carle Place, NY. EMSL is accredited by the American Industrial Hygiene Association (AIHA) for microbial analysis and participates in the Environmental Microbiology Laboratory Accreditation Program (EMLAP).

Guidance

The Occupational Safety and Health Administration's (OSHA) Permissible Exposure Limits (PELs) are the only enforceable regulatory standards for indoor air quality. However, other organizations such as the American Society of Heating Refrigeration and Air Conditioning Engineers (ASHRAE) and the Environmental Protection Agency (EPA) have developed widely accepted consensus standards that can be used to assess the suitability of indoor air quality.

ASHRAE Standards

62.1-2013 and 55-2013 are consensus standards that outline acceptable practices for the design of ventilation systems in commercial and residential structures. Both documents were developed "to specify minimum ventilation rates and indoor air quality that will be acceptable to human occupants and are intended to minimize the potential for adverse health effects." The standards also consider chemical, physical, and biological contaminants and other factors that impact indoor air quality and affect occupant health and comfort.

ASHRAE 55-2013 recommends temperature and relative humidity ranges that are considered suitable for indoor air quality. Recommended ranges are as follows:

- Temperature be maintained between 67 and 82 degrees Fahrenheit (°F)
- Relative humidity to be maintained below 65%

Carbon Dioxide

CO₂ is widely used as a surrogate gas in the assessment of indoor air quality. It is a byproduct of respiration and can be used to determine the effectiveness and/or management of building ventilation systems. Based on ASHRAE recommendations, indoor CO₂ concentrations that are below 1000 parts per million (ppm) or have a differential of less than 700 ppm compared to outside concentrations are considered to be suitable.

For example, if outside CO₂ concentrations are measured at 380 ppm, then indoor CO₂ concentrations measured up to 1080 ppm would be considered suitable.

Carbon Monoxide

OSHA has established a PEL for CO of 35 ppm over a time weighted average (TWA) of 8 hours and a ceiling CO exposure limit of 200 ppm in a five-minute period. ASHARE has adopted the EPA National Ambient Air Quality Standard (NAAQS) for CO of 9 ppm when evaluating indoor air quality. In nonindustrial settings, the NAAQS standard is commonly used to assess the suitability of IAQ.

Nonviable Airborne Fungi (Mold)

There are no set regulatory limits established for acceptable airborne fungi levels. However, indoor levels within schools and offices are generally lower than outdoor levels. The distribution of airborne species of fungi found in indoor air is expected to be similar in proportion to outside distributions. The type and concentrations of the airborne microorganisms can be used to determine if there is a potential hazard to occupants which requires action.

Findings

Indoor Air Quality

With the exception of the high relative humidity recorded in the gymnasium, the indoor air quality measurements collected were satisfactory with respect to temperature, relative humidity, carbon dioxide (CO₂), and carbon monoxide (CO). Recorded indoor air quality results are summarized in the following Table.

Table 1				
Indoor Air Quality Measurement Summary				
(Measurements Recorded on May 25, 2019)				
Measurement Location	Temperature (°F)	Relative Humidity (%)	CO₂ (ppm)	CO (ppm)
Classroom 215	71.5	55.3	465	0.0
Classroom 204	70.6	56.2	486	0.0
Classroom 206	71.6	54.6	506	0.0
Classroom 209	71.5	54.2	405	0.0
Classroom 122	67.1	56.5	460	0.0
Classroom 133	68.5	51.4	489	0.0
Classroom 139	68.8	51.9	502	0.0
Auditorium	72.2	57.2	471	0.0
Room 149	67.7	51.3	479	0.0
Cafetorium	71.6	57.1	448	0.0
Classroom 225	70.2	58.7	476	0.0
Classroom 239	70.0	59.0	473	0.0
Classroom 247	69.3	59.8	471	0.0
Classroom 220	69.9	60.0	475	0.0
Gymnasium	73.6	73.5	469	0.0
Classroom 118	70.3	56.1	491	0.0
Classroom 113	70.9	57.9	488	0.0
Classroom 114	71.0	56.5	496	0.0
Classroom 108	71.9	55.3	491	0.0
Classroom 128	67.6	57.4	477	0.0
Basement Lower Gym	73.4	57.7	466	0.0
Outdoors	72.9	56.3	480	0.0

ppm – parts per million

Non-viable Airborne Fungi Sampling

Measured total indoor airborne fungi concentrations were determined have a normal ecology and with indoor airborne fungi concentrations lower than measured total outdoor fungi concentrations at this time. A complete laboratory analysis report is available for viewing in Attachment A.

Visual Assessment

A walk-through of the hallways and a limited number of classrooms and public areas was carried out. No bathrooms, staff offices, mechanical rooms, kitchen areas or storage areas were visited. The school was not in session at the time of the inspection.

The school was free of evidence of current water intrusion or any unexpected odors. Except as noted, floors, walls and ceiling tiles observed were in acceptable condition. The housekeeping was acceptable.

The following areas for further investigation or improvement were noted:

- Rooms 209, 122, 139, 149, 113, 108 – stained ceiling tiles observed
- Auditorium – stained ceiling on two sides of sound booth
- Cafetorium – stained ceiling tile near dishwashing door

Conclusions & Recommendations

Indoor air quality spore trap measurements collected in all areas assessed were less than the levels measured outside the building and with the same predominate spore types found. This is an indication that the spores sampled in the rooms assessed are more likely to be originating in the outdoor environment rather than an interior source - reducing the chance of undetected overgrowth or colonization in the building. While there are no standards for airborne levels of mold, this approach of comparing indoor to outdoor, and looking at the species found, is one tool identified by organizations such as the American Industrial Hygiene Association when identifying assessment methods and improvement measurement in indoor air quality. Please note the following considerations for improvement.

- Identify the cause of any staining on ceiling tiles and fix
- If possible, reduce the humidity levels in the gymnasium

At this time, no other recommendations are provided. Windjammer appreciates the opportunity to provide this indoor air quality assessment. If you have any questions or comments, please feel free to contact us at (888) 270 - 8387.

Best regards,

A black ink handwritten signature, appearing to be 'D Hammond Sr', with a large, stylized 'D' and a long horizontal stroke.

Damien Hammond Sr, MS, CSP, CIH
President

A blue ink handwritten signature, appearing to be 'K Dietrich', with a stylized 'K' and a long horizontal stroke.

Katherine (Kay) Dietrich, CIH, CSP
Certified Industrial Hygienist

Attachment A: Microbial Laboratory Report (Air)

Attachment A



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPs IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0001			061910229-0002			061910229-0003		
Client Sample ID:	190525-1			190525-2			190525-3		
Volume (L):	75			75			75		
Sample Location	Rm 215			Rm 204			Rm 206		
Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total
Alternaria (Ulocladium)	-	-	-	1	40	2.1	-	-	-
Ascospores	5	200	10.3	7	300	15.5	2	90	15.8
Aspergillus/Penicillium	1	40	2.1	2	90	4.7	1	40	7
Basidiospores	39	1700	87.6	34	1500	77.7	10	440	77.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	45	1940	100	44	1930	100	13	570	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPS IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0004			061910229-0005			061910229-0006		
Client Sample ID:	190525-4			190525-5			190525-6		
Volume (L):	75			75			75		
Sample Location	Rm 209			Rm 122			Rm 133		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	12	520	18.7	-	-	-	4	200	17.7
Aspergillus/Penicillium	3	100	3.6	-	-	-	3	100	8.8
Basidiospores	47	2100	75.5	5	200	100	19	830	73.5
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	1	40	1.4	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	1*	10*	0.4	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	1*	10*	0.4	-	-	-	-	-	-
Total Fungi	65	2780	100	5	200	100	26	1130	100
Hypthal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745


Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPS IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0007			061910229-0008			061910229-0009		
Client Sample ID:	190525-7			190525-8			190525-9		
Volume (L):	75			75			75		
Sample Location	Rm 139			Auditorium			Rm 149		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	3	100	8.9	-	-	-	-	-	-
Aspergillus/Penicillium	3	100	8.9	-	-	-	3	100	25
Basidiospores	21	920	82.1	2	90	100	6	300	75
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	27	1120	100	2	90	100	9	400	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPs IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0010			061910229-0011			061910229-0012		
Client Sample ID:	190525-10			190525-11			190525-12		
Volume (L):	75			75			75		
Sample Location	Cafetorium			Rm 225			Rm 239		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	4	200	8.8	5	200	11.6
Aspergillus/Penicillium	-	-	-	15	660	29.2	2	90	5.2
Basidiospores	-	-	-	27	1200	53.1	32	1400	80.9
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	4	200	8.8	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	1	40	2.3
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	-	No Trace	-	50	2260	100	40	1730	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	-	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	-	-	-	1	-	-	1	-
Background (1-5)	-	-	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPs IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0013			061910229-0014			061910229-0015		
Client Sample ID:	190525-13			190525-14			190525-15		
Volume (L):	75			75			75		
Sample Location	Rm 247			Rm 220			Gym		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	1	40	1.5
Ascospores	8	300	10.3	4	200	13.3	10	440	16.8
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	59	2600	89	29	1300	86.7	48	2100	80.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	1*	10*	0.3	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	1*	10*	0.3	-	-	-	1	40	1.5
Total Fungi	69	2920	100	33	1500	100	60	2620	100
Hyphal Fragment	-	-	-	-	-	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	1	40	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPs IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0016			061910229-0017			061910229-0018		
Client Sample ID:	190525-16			190525-17			190525-18		
Volume (L):	75			75			75		
Sample Location	Rm 118			Rm 113			Rm 114		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	3	100	9.4	14	610	15.6	1	40	2.5
Aspergillus/Penicillium	-	-	-	2	90	2.3	1	40	2.5
Basidiospores	21	920	86.8	72	3100	79.5	33	1400	89.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	1	40	3.8	3	100	2.6	2	90	5.7
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	25	1060	100	91	3900	100	37	1570	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	1	40	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPs IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0019			061910229-0020			061910229-0021		
Client Sample ID:	190525-19			190525-20			190525-21		
Volume (L):	75			75			75		
Sample Location	Rm 108			Rm 128			Basement Gym		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	6	300	21	3	100	9.9	2	90	12.2
Aspergillus/Penicillium	7	300	21	1	40	4	2	90	12.2
Basidiospores	17	740	51.7	19	830	82.2	12	520	70.3
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	2	90	6.3	-	-	-	1	40	5.4
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	1	40	4	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	32	1430	100	24	1010	100	17	740	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910229
Customer ID: WJEN42
Customer PO: Auth #92936G
Project ID:

Attn: Kay Dietrich
Windjammer Environmental
6710 Oxon Hill Rd
National Harbor, MD 20745

Phone: (301) 351-4213
Fax:
Collected: 05/25/2019
Received: 05/28/2019
Analyzed: 05/30/2019 - 05/31/2019

Project: PGCPs IAQ Friendly HS, MD

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910229-0022		
Client Sample ID:	190525-22		
Volume (L):	75		
Sample Location	Outdoor		
Spore Types	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	1*	10*	0.2
Ascospores	18	790	17.7
Aspergillus/Penicillium	-	-	-
Basidiospores	71	3100	69.4
Bipolaris++	-	-	-
Chaetomium	-	-	-
Cladosporium	12	520	11.6
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium	-	-	-
Ganoderma	1	40	0.9
Myxomycetes++	1*	10*	0.2
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
Polythrincium	-	-	-
Total Fungi	104	4470	100
Hypchal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	1	40	-
Analyt. Sensitivity 600x	-	44	-
Analyt. Sensitivity 300x	-	13*	-
Skin Fragments (1-4)	-	1	-
Fibrous Particulate (1-4)	-	1	-
Background (1-5)	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

No discernable field blank was submitted with this group of samples.

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/03/2019 18:30:20

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com