



4221 Forbes Boulevard · Suite 250
Landover Hills, Maryland 20784
T: 202.558.7487 | <http://atiinc.com/>

June 13, 2019

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Screening, Glenridge Elementary School
IFB: 022-19
ATI Project Number: ATI19-683

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc. conduct a proactive indoor air quality (IAQ) screening at Glenridge Elementary School. The IAQ screening was conducted on May 29, 2019. Its key findings are enclosed in the Executive Summary on page three, and the official laboratory report for total fungal spore trap sampling is enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,
ATI, INC.

Courtney E. McCall
Project Manager

Sarath Seneviratne
CIH, CSP, CHMM

Indoor Air Quality Screening Report



Prince George's County Public Schools
Glenridge Elementary School
7200 Gallatin Street
Landover Hills, Maryland 20784

Prepared for:

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772

June 13, 2019

Submitted by:

The logo for ATI (Air Technology, Inc.) consists of the lowercase letters "ati" in a bold, blue, sans-serif font. The letters are lowercase and the "i" has a dot.

ATI Job # 19-683

Intentionally Blank

Table of Contents

1. Executive Summary and Key Findings 3

2. Assessment Methods..... 3

3. Visual Observations 4

4. Thermal Environmental Conditions for Human Occupancy 5

 4.1 Temperature..... 5

 4.2 Relative Humidity 6

 4.3 Carbon Dioxide 7

 4.4 Carbon Monoxide..... 8

5. Total Fungal Air Sampling Results..... 8

6. Summary of Findings..... 9

Table 1: Visual Observations and Sampling Locations..... 4

Table 2: Temperature Measurements 6

Table 3: Relative Humidity Measurements..... 6

Table 4: Carbon Dioxide Measurements..... 7

Table 5: Carbon Monoxide Measurements 8

Appendix A: Laboratory Report and Chain of Custody
Appendix B: Instrument Calibration Records



Abbreviations and Acronyms

AHU	Air-Handling Unit
AIHA	American Industrial Hygiene Association
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
ASTM	American Society for Testing and Materials
CO	Carbon Monoxide
CO₂	Carbon Dioxide
EMLAP	Environmental Microbiology Laboratory Accreditation Program
HVAC	Heating, Ventilating, And Air-Conditioning
IAQ	Indoor Air Quality
NIST	National Institute for Standards and Technology
NVLAP	National Voluntary Laboratory Accreditation Program
RH	Relative Humidity

Abbreviations involving scientific volume and measurements involving media or water sampling

Counts/m³	Mold spores per cubic meter of air
LPM	Liters Per Minute
NTE	Not to exceed
°F	degree Fahrenheit
PPM	Parts Per Million

1. Executive Summary and Key Findings

ATI conducted a proactive Indoor Air Quality (IAQ) screening on May 29, 2019, at Glenridge Elementary School, located at 7200 Gallatin Street, Landover Hills, MD 20784.

The screening included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria, the main office, and classrooms, for potential IAQ contributors and pathways. As part of the screening, ATI collected direct reading measurements for comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from this screening:

1. Two locations were cooler than the recommended ASHRAE summer comfort range, between 73°F and 79°F.
2. Relative humidity measurements were within ASHRAE guidelines, <65%.
3. Three locations exceeded the recommended ASHRAE limit for carbon dioxide, which was 1,006.5 parts per million (PPM).
4. Carbon monoxide levels were below the ASHRAE standard of nine ppm.
5. Total spore counts in each tested location did not exceed those detected outdoors, 23,430 counts/m³. Ascospores, Basidiospores, and Aspergillus/Penicillium were all detected at levels above the outdoor sample in one indoor location. These spore types are known to cause allergies.

2. Assessment Methods

Ms. Mikal Frater of ATI, Inc. conducted a visual assessment and air sampling on May 29, 2019. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Visual observations were made at the time the samples were collected. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents the breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO₂), and carbon monoxide (CO), were obtained with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. The samples were analyzed by direct microscopic examination (identifies and counts both viable and non-viable spores, which is then considered “total fungal”), via the American Society for Testing and Materials (ASTM) Standard D7391-09 by EMSL Analytical, Inc., (EMSL) located in Beltsville, MD.

EMSL participates in the National Institute of Standards and Technology’s (NIST’s) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management and the American Industrial Hygiene Association (AIHA) Environmental Microbial Laboratory Accreditation Program (EMLAP, Certificate Number 102891).

Instrument calibration records are included in Appendix B of this report.

3. Visual Observations

Table 1: Visual Observations and Sampling Locations

Sample Location	Observations
Outside	<ul style="list-style-type: none"> • Light traffic. • Clear, sunny skies. • Light winds. • One occupant in sampling area.
Main Office	<ul style="list-style-type: none"> • A/C is loud, so staff keeps it off. • Four occupants in sampling area. • Individual fan – OFF during sampling. • Space splits into additional offices. • One air return, two air diffusers. • Space is approximately 320 ft.²
Room 200	<ul style="list-style-type: none"> • Paint products over wall unit. • Friedrich A/C on – very high up, so cold air cannot be felt. • Door to corridor open. • Twenty-one occupants in sampling area. • One individual oscillating fan is OFF during sampling. • One air return. • Space is approximately 720 ft.²
Room 104	<ul style="list-style-type: none"> • Four air returns. • Old roof, flat top. Water sits in the middle of the roof, while drains are on the roof perimeter. History of leak two weeks prior. • One wall unit. • Two A/C units – ON and can be felt. • 17 plants growing along window. • Two occupants in sampling area. • Ceiling tile missing – assumed leak remediation. • Door to corridor open. • Space is approximately 880 ft.²
Gymnasium	<ul style="list-style-type: none"> • Fans letting in outside air. One fan not in operation. Belts on fan replaced. • Two individual oscillating fans – ON. • Outside door open. • Three occupants in sampling area. • NO A/C. • Six heat vents.

Sample Location	Observations
	<ul style="list-style-type: none"> • Large occupied area.
Room 112	<ul style="list-style-type: none"> • One air return. Newer model Friedrich A/C – OFF. • Individual oscillating fan – OFF • Three stained ceiling tiles over whiteboard. • Two wall units. • 25 occupants in area during sampling. • A/C very high up – might be too high up to feel air. • Space is approximately 880 ft.²
Room 223	<ul style="list-style-type: none"> • One air return, one air diffuser. • Two individual oscillating fans – OFF. • Friedrich A/C ON – cannot feel cold air. • One wall unit. • 25 occupants in sampling area. • Light in classroom flickering. • Space is approximately 800 ft.²
Room 215	<ul style="list-style-type: none"> • One air return. • 32 occupants about 4/5 ft. from sampling area. • A/C on with the window open directly underneath. • One individual oscillating fan – OFF. • 28 plants below A/C next to wall unit. • One wall unit. • Door to corridor open. • Space is approximately 800 ft.²

4. Thermal Environmental Conditions for Human Occupancy

ASHRAE Standard 55-2017, *Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy most building occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperature measurements obtained during the May 29, 2019, screening is summarized in Table 2. As indicated by the data in the table, temperatures in the school averaged between 68.4 – 77.0°F. Two locations were cooler than the ASHRAE recommended summer range.

Table 2: Temperature Measurements

Sample Location	May 29, 2019 °F			ASHRAE Standard °F
	Min	Max	Average	
Outside	83.9	83.3	83.1	N/A
Indoors				
Main Office	74.8	74.3	74.55	73 – 79
Room 200	75.2	75.8	75.5	73 – 79
Room 104	68.4	68.4	68.4	73 – 79
Gymnasium	76.4	77.6	77.0	73 – 79
Room 112	73.7	73.7	73.7	73 – 79
Room 223	69.2	70.2	69.7	73 – 79
Room 215	73.5	73.5	73.5	73 – 79

4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity below 30% may result in drying of the mucous membranes and skin. Relative humidity measurements are summarized in Table 3. As indicated by the data in the table, relative humidity measurements averaged between 45.4 and 64.0%, below the ASHRAE maximum recommendation of 65% relative humidity.

Table 3: Relative Humidity Measurements

Sample Location	May 29, 2019 (%)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outside	48.3	48.6	48.45	N/A
Inside				
Main Office	47.5	48.1	47.8	< 65
Room 200	48.7	49.7	49.2	< 65
Room 104	59.8	60.2	60.0	< 65
Gymnasium	62.7	65.3	64.0	< 65
Room 112	45.3	47.1	46.2	< 65
Room 223	42.2	48.6	45.4	< 65
Room 215	50.4	50.4	50.4	< 65

4.3 Carbon Dioxide

Carbon dioxide measurements within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation results indoor carbon dioxide concentrations are less than 700 parts per million (ppm) above the outdoor air concentration.

Carbon dioxide measurements are summarized in Table 4. On the day of the screening, the average outdoor carbon dioxide concentration obtained was 306.5 ppm, which calculates to a maximum indoor concentration of 1,006.5 ppm (700 + 306.5). The carbon dioxide levels inside the school ranged from the average minimum detected, 535.5 ppm to 1,839 ppm, the average maximum detected. Three locations exceeded the maximum recommended concentration of 1,006.5 ppm.

Table 4: Carbon Dioxide Measurements

Sample Location	May 29, 2019 Concentration (parts per million)			ASHRAE Standard (ppm) NTE
	Min	Max	Average	
Outside	298	315	306.5	N/A
Inside				
Main Office	943	965	954	1,006.5
Room 200	529	542	535.5	1,006.5
Room 104	1,105	1,109	1,107	1,006.5
Gymnasium	631	695	663	1,006.5
Room 112	1,747	1,931	1,839	1,006.5
Room 223	1,584	1,586	1,585	1,006.5
Room 215	848	956	902	1,006.5

4.4 Carbon Monoxide

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors. As indicated by the data in Table 5, carbon monoxide levels were below the ASHRAE standard of nine ppm.

Table 5: Carbon Monoxide Measurements

Sample Location	May 29, 2019 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outside	0	0	0	N/A
Inside				
Main Office	0	0	0	< 9
Room 200	0	0	0	< 9
Room 104	0	0	0	< 9
Gymnasium	0	0	0	< 9
Room 112	0	0	0	< 9
Room 223	0	0	0	< 9
Room 215	0	0	0	< 9

5. Total Fungal Air Sampling Results

Mold needs a food source, moisture, proper temperature and humidity, and at times, a source of light, to grow in an environment. Air infiltration through building entrances and exits, open windows and loading docks, and foot traffic into buildings, including the HVAC system all serve as primary pathways that can carry fungi indoors. Water leaks and humid conditions inside of buildings provide the moisture that fosters mold growth.

The May 29, 2019, mold screening sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building's HVAC system.

The official laboratory report with spore trap samples collected on May 29, 2019, is presented in Appendix A. The findings indicated that the indoor concentrations were favorable compared to the outdoor concentrations. Total spore counts in each tested location did not exceed those detected outdoors, 23,430 counts/m³.

Ascospores, Basidiospores and Cladosporium, mold spores that are commonly detected indoors, were the predominant spore types. Each are known to cause allergies yet are not associated with water damaged materials in buildings.

Ascospores and Basidiospores were each detected indoors, and in some cases, at levels above the ambient. Ascospores were elevated in the gymnasium, at 1,400 counts/m³, while the outdoor sample detected 700 counts/m³. Basidiospores were elevated in Room 200, at 9,600 counts/m³, while the outdoor sample detected 6,850 counts/m³.

Aspergillus/Penicillium, which is also known to cause allergies, was detected in Room 104 with 1,500 counts/m³, while the ambient was 830 counts/m³.

6. Summary of Findings

Two locations were cooler than the recommended ASHRAE summer comfort range, between 73°F and 79°F. Relative humidity measurements were within ASHRAE guidelines, <65%. Three locations exceeded the recommended ASHRAE limit for carbon dioxide, which was 1,006.5 parts per million (PPM). Carbon monoxide levels were below the ASHRAE standard of nine ppm.

Total spore counts in each tested location did not exceed those detected outdoors, 23,430 counts/m³. Ascospores, Basidiospores, and Aspergillus/Penicillium were all detected at levels above the outdoor sample in one indoor location. These spore types are known to cause allergies.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Sincerely,
ATI, INC.



Courtney E. McCall
Project Manager



Sarath Seneviratne
CIH, CSP, CHMM

**Appendix A:
Laboratory Report and Chain of Custody**



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / beltsvillelab@emsl.com

EMSL Order: 191906175

Customer ID: ATII25

Customer PO:

Project ID:

Attn: Courtney McCall
ATI
10205 Sutherland Road
Silver Spring, MD 20901

Phone: (703) 399-5423

Fax: (202) 643-4284

Collected: 05/29/2019

Received: 05/29/2019

Analyzed: 05/31/2019 - 06/03/2019

Project: 19-683- PGCPs- GLENRIDGE ES

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906175-0001 19-683-01 75 OUTSIDE PARKING LOT			191906175-0002 19-683-02 FIELD BLANK			191906175-0003 19-683-03 75 MAIN OFFICE		
Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total
Alternaria (Ulocladium)	5	200	0.9	-	-	-	-	-	-
Ascospores	16	700	3	-	-	-	12	520	6.5
Aspergillus/Penicillium	19	830	3.5	-	-	-	6	300	3.7
Basidiospores	157	6850	29.2	-	-	-	108	4710	58.5
Bipolaris++	1	40	0.2	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	319	13900	59.3	-	-	-	55	2400	29.8
Curvularia	1	40	0.2	-	-	-	-	-	-
Epicoccum	4	200	0.9	-	-	-	1	40	0.5
Fusarium	3	100	0.4	-	-	-	1	40	0.5
Ganoderma	1	40	0.2	-	-	-	-	-	-
Myxomycetes++	9	400	1.7	-	-	-	1	40	0.5
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Botrytis	-	-	-	-	-	-	-	-	-
Cercospora++	1	40	0.2	-	-	-	-	-	-
Pestalotia/Pestalotiopsis	-	-	-	-	-	-	-	-	-
Polythrincium	1*	10*	0	-	-	-	-	-	-
Sporidesmium-like	1	40	0.2	-	-	-	-	-	-
Sporormiella	-	-	-	-	-	-	-	-	-
Torula-like	1	40	0.2	-	-	-	-	-	-
Total Fungi	539	23430	100	-	No Trace	-	184	8050	100
Hypal Fragment	6	300	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	3	100	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	0	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	0*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	-	-	-	4	-
Fibrous Particulate (1-4)	-	1	-	-	-	-	-	1	-
Background (1-5)	-	2	-	-	-	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "*" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/05/2019 10:35:12

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com / beltsvillelab@emsl.com>

EMSL Order: 191906175
Customer ID: ATII25
Customer PO:
Project ID:

Attn: Courtney McCall ATI 10205 Sutherland Road Silver Spring, MD 20901	Phone: (703) 399-5423 Fax: (202) 643-4284 Collected: 05/29/2019 Received: 05/29/2019 Analyzed: 05/31/2019 - 06/03/2019
Project: 19-683- PGCPS- GLENRIDGE ES	

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906175-0004 19-683-04 75 ROOM 200			191906175-0005 19-683-05 75 ROOM 104			191906175-0006 19-683-06 75 GYNASIUM			
	Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	1	40	0.2	-	-	-	-	-	-	-
Ascospores	16	700	3.3	5	200	6.5	33	1400	8.5	
Aspergillus/Penicillium	8	300	1.4	34	1500	49	3	100	0.6	
Basidiospores	220	9600	45.3	20	870	28.4	144	6280	38	
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-	-
Cladosporium	233	10200	48.1	10	440	14.4	195	8510	51.5	
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	1	40	0.2	-	-	-	2	90	0.5	
Fusarium	-	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	0.2	-	-	-	-	-	-	-
Myxomycetes++	2	90	0.4	-	-	-	3	100	0.6	
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	1	40	1.3	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Botrytis	2	90	0.4	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Pestalotia/Pestalotiopsis	-	-	-	1*	10*	0.3	-	-	-	-
Polythrincium	2	90	0.4	-	-	-	-	-	-	-
Sporidesmium-like	-	-	-	-	-	-	-	-	-	-
Sporormiella	-	-	-	-	-	-	-	-	-	-
Torula-like	-	-	-	-	-	-	1	40	0.2	
Total Fungi	486	21190	100	71	3060	100	381	16520	100	
Hypthal Fragment	3	100	-	-	-	-	2	90	-	
Insect Fragment	-	-	-	-	-	-	2	90	-	
Pollen	1	40	-	-	-	-	-	-	-	
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	
Skin Fragments (1-4)	-	4	-	-	2	-	-	4	-	
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	
Background (1-5)	-	2	-	-	1	-	-	2	-	

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. * Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/05/2019 10:35:12

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com/beltsvillelab@emsl.com>

EMSL Order: 191906175

Customer ID: ATII25

Customer PO:

Project ID:

Attn: Courtney McCall
ATI
10205 Sutherland Road
Silver Spring, MD 20901

Phone: (703) 399-5423

Fax: (202) 643-4284

Collected: 05/29/2019

Received: 05/29/2019

Analyzed: 05/31/2019 - 06/03/2019

Project: 19-683- PGCPs- GLENRIDGE ES

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	191906175-0007			191906175-0008			191906175-0009		
Client Sample ID:	19-683-07			19-683-08			19-683-09		
Volume (L):	75			75			75		
Sample Location	ROOM 112			ROOM 223			ROOM 215		
Spore Types	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total	Raw Count	Count/m ³	% of Total
Alternaria (Ulocladium)	1	40	1.5	-	-	-	2*	30*	0.7
Ascospores	4	200	7.3	1	40	2	6	300	6.8
Aspergillus/Penicillium	3	100	3.6	5	200	10.1	3	100	2.3
Basidiospores	39	1700	62	19	830	41.9	62	2700	61.6
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	14	610	22.3	20	870	43.9	27	1200	27.4
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	1	40	0.9
Myxomycetes++	2	90	3.3	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	1	40	2	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Botrytis	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Pestalotia/Pestalotiopsis	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Sporidesmium-like	-	-	-	-	-	-	-	-	-
Sporormiella	-	-	-	-	-	-	1*	10*	0.2
Torula-like	-	-	-	-	-	-	-	-	-
Total Fungi	63	2740	100	46	1980	100	102	4380	100
Hypthal Fragment	2	90	-	-	-	-	1*	10*	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	1	40	-	1	40	-	1	40	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	4	-	-	4	-	-	4	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	2	-
Background (1-5)	-	1	-	-	1	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/05/2019 10:35:12

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Microbiology Chain of Custody
EMSL Order Number (Lab Use Only):

191906175

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: (800) 220-3675
FAX: (856) 786-0262

Company Name: ATI, Inc			EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments				
Street: 4221 Rumsey Road, Suite 250			Third Party Billing requires written authorization from third party.				
City: Lanham		State/Province: MD		Zip/Postal Code: 20706		Country:	
Report To (Name): Courtney McCall / Mikal Frater			Telephone #: 202-558-7489				
Email Address: Courtney@atiinc.com & Mikal@atiinc.com			Fax #:		Purchase Order:		
Project Name/Number: 19-683- PGCPs - Glenridge ES			Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email				
U.S. State Samples Taken:		Project Zip Code:		Connecticut Samples: <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Residential			
Sterile, Sodium Thiosulfate Preserved Bottle Used: <input type="checkbox"/> Biocide Used in Source (specify): <input type="checkbox"/>							
Public Water Supply Samples: <input type="checkbox"/> Note: All results may automatically be reported to DOH if required by state.							
Turnaround Time (TAT) Options - Please Check							
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input checked="" type="checkbox"/> 1 Week	<input type="checkbox"/> 2 Week
Microbiology Test Codes							
M001 Air-O-Cell		M174 MoldSnap		M012 Pseudomonas aeruginosa (P/A***)		M115 Sewage Screen - Water (P/A***)	
M030 Micro 5		M032 Allergenco-D		M024 Pseudomonas aeruginosa (MFT*)		M116 Sewage Screen - Water (MPN**)	
M041 Fungal Direct Examination				M015 Heterotrophic Plate Count		M117 Sewage Screen - Swab (P/A***)	
M169 Pollen ID & Enumeration				M017 Total Coliform & E. coli (Colilert P/A***)		M013 Sewage Screen - Swab (MFT*)	
M280 Dust Characterization Level-1				M018 Total Coliform & E. coli (MFT*)		M133 Methicillin-resistant Staph. aureus (MRSA)	
M281 Dust Characterization Level-2				M114 Total Coliform & E. coli Enumeration (Colilert MPN**)		M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration	
M005 Viable Fungi- Air Samples (Genus ID & Count)				M019 Fecal Coliform (MFT*)		M014 Endotoxin Analysis	
M006 Viable Fungi- Air Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)				M020 Fecal Streptococcus (MFT*)		M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite)	
M007 Culturable fungi - Surface Samples (Genus ID & Count)				M029 Enterococci (MFT*)		Other See Analytical Price Guide	
M008 Culturable fungi - Surface Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)				M129 Enterococci (Enterolert P/A***)		Legionella Analysis Please use EMSL Legionella COC	
M009 Bacteria Culture Gram Stain & Count				M180 Real Time qPCR-ERMI 36 Panel			
M010 Bacteria Count & ID - 3 Most Prominent				M025 Sewage Screen -Water (MFT*)			
M011 Bacteria Count & ID - 5 Most Prominent				*MFT= Membrane Filtration Technique			
				**MPN= Most Probable Number			
				***P/A= Presence/Absence			
Name of Sampler: Mikal Frater				Signature of Sampler:			
Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
Example A1	Kitchen Sink/Tap	Water	<input checked="" type="checkbox"/> P <input type="checkbox"/> NP	M017	100 mL	9/1/13 4:00 PM	
19-683-01	Outside Parking Lot	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 10:50	
19-683-02	Field Blank	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 -	
19-683-03	Main Office	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 11:13	
19-683-04	Room 200	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 11:33	
19-683-05	Room 104	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 11:43	
Client Sample # (s): 9		Total # of Samples: 9		Samples Received Chilled? Yes / No (Lab Use Only)			
Relinquished (Client):			Date: 5-29-19		Time: 4:25 pm		
Received (Lab):			Date: 5/30/19		Time: 4:25 pm		
Comments/Special Instructions:							

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



Microbiology Chain of Custody
 EMSL Order Number (Lab Use Only):

191906175

EMSL ANALYTICAL, INC.
 200 ROUTE 130 NORTH
 CINNAMINSON, NJ 08077
 PHONE: (800) 220-3675
 FAX: (856) 786-0262

Additional pages of the chain of custody are only necessary if needed for additional sample information.

Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
19-683-06	Gymnasium	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 11:55	
19-683-07	Room 112	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 12:14	
19-683-08	Room 223	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 12:27	
19-683-09	Room 215	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-29-19 - 12:39	
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
Comments/Special Instructions:							

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Controlled Document – COC-34 Micro R8 11/14/2017

**Appendix B:
Instrument Calibration Records**

Certificate of Calibration

() Buck™ BioAire Pump Calibration Rotameter

() Buck™ BioSlide Pump Calibration Rotameter

Serial number: R14057

Date Calibrated: 1/22/19

Calibration Due Date: 1/22/20

Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within $\pm 5\%$ of the actual flow rate.

AMBIENT CONDITIONS: Temperature $74 \pm 3^{\circ}$ F Relative Humidity $50 \pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: 

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.
7101 Presidents Drive, Suite 110
Orlando, FL 32809
Phone: 407-851-8602
Fax: 407-851-8910

BUCK
A.P. BUCK, INC.



INSTRUMENT CALIBRATION REPORT

Pine Environmental Services LLC

798 Cromwell Park Dr.
Suite R & S
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID 27136
Description TSI 982 Probe
Calibrated 5/28/2019 12:36:30PM

Manufacturer Tsi
Model Number 982
Serial Number/ Lot Number p13220024
Location Maryland
Department
State Certified
Status Pass
Temp °C 22
Humidity % 53

Calibration Specifications

Group # 1				Range Acc % 0.0000			
Group Name CO				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0.0			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
100.0 / 100.0	PPM	100.0	PPM	108.0	100.0	0.00%	Pass
Group # 2				Range Acc % 0.0000			
Group Name CO2				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
1000 / 1000	PPM	1000	PPM	982	1,000	0.00%	Pass

Test Instruments Used During the Calibration

<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>(As Of Cal Entry Date)</u>	
					<u>Last Cal Date / Opened Date</u>	<u>Next Cal Date / Expiration Date</u>
MD 2GAS CO 100PPM/CO2 1000PPM	MD 2GAS CO 100PPM/CO2 1000PPM - LBI-375-2	Pine Environmental Services, Inc.	31657	LBI-375-2		11/21/2022
MD ZERO AIR FBI-1-25	MD ZERO AIR	Pine Environmental Services, Inc.	34LS-1	FBI-1-25		

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Ryan Armstrong

INSTRUMENT CALIBRATION REPORT



Pine Environmental Services LLC

798 Cromwell Park Dr.
Suite R & S
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID 27136
Description TSI 982 Probe
Calibrated 5/28/2019 12:36:30PM

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment
Please call 800-301-9663 for Technical Assistance

INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

Pine Environmental Services, Inc

Instrument ID 27136
 Description TSI 982 Probe
 Calibrated 12/12/2018

Manufacturer TSI
 Model Number 982
 Serial Number P13220024
 Location New Jersey
 Temp 71

Classification
 Status pass
 Frequency Yearly EOM
 Department Lab
 Humidity 22

Calibration Specifications

Group # 1							
Group Name Carbon Dioxide				Range Acc %	0.0000		
Stated Accy Pct of Reading				Reading Acc %	3.0000		
				Plus/Minus	0.00		
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
0.00 / 0.00	ppm	0.00	ppm	0.00	0.00	0.00%	Pass
1000.00 / 1000.00	ppm	1000.00	ppm	1,009.00	1,002.00	0.20%	Pass
Group # 2				Range Acc %	0.0000		
Group Name Carbon Monoxide				Reading Acc %	3.0000		
Stated Accy Pct of Reading				Plus/Minus	0.00		
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
0.00 / 0.00	ppm	0.00	ppm	4.60	0.00	0.00%	Pass
100.00 / 100.00	ppm	100.00	ppm	96.00	100.10	0.10%	Pass
Group # 3				Range Acc %	0.0000		
Group Name Relative Humidity				Reading Acc %	3.0000		
Stated Accy Pct of Reading				Plus/Minus	0.00		
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
50.00 / 30.80	%	30.80	%	31.00	30.80	0.00%	Pass
Group # 4				Range Acc %	0.0000		
Group Name Temperature				Reading Acc %	0.0000		
Stated Accy Plus / Minus				Plus/Minus	1.00		
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
65.00 / 72.30	°F	72.30	°F	69.80	72.30	0.00%	Pass

Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
CO/CO2_34LS-375	100 ppm CO, 1000 ppm CO2	Calgaz	MAO-375-1		6/9/2019
MICHELL DM-509-TX-01	Relative Humidity Meter	Michell	273296	9/17/2018	9/17/2019
NITROGEN ZERO_AIR_105	Nitrogen 99.999%	Liquid Technology	7727-37-9	6/1/2016	6/1/2019
L-1	Zero Grade Air THC <1.0 PPM	Liquid Technology	KAP-A-10	10/1/2015	10/20/2019

INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

Pine Environmental Services, Inc

Instrument ID 27136
Description TSI 982 Probe
Calibrated 12/12/2018

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Kevin Cole

Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.

INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

Pine Environmental Services, Inc

Instrument ID R20401
 Description TSI 7575 -X Q-Trak
 Calibrated 8/22/2018

Manufacturer TSI
 Model Number 7575-X
 Serial Number 7575X1130009
 Location New Jersey
 Temp 77

Classification
 Status pass
 Frequency Yearly EOM
 Department Lab
 Humidity 41

Calibration Specifications

Group # 1		Range Acc % 0.0000	
Group Name Barometric Pressure		Reading Acc % 3.0000	
Stated Accy Pct of Reading		Plus/Minus 0.000	
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>
30.000 / 29.610	inHg	29.610	inHg
		<u>End As</u>	<u>Lft As</u>
		29.620	29.610
		<u>Dev%</u>	<u>Pass/Fail</u>
		0.00%	Pass

Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
OMEGA HX93AC/DP25- E	Omega HX93AC/DP25-E	Omega Engineering	1010368 035025 035026	9/15/2016	9/15/2018
OMEGA PX02K1-16A5T /DP25-E-A	Omega PX02K1-16A5T/DP25-E-A	Omega Engineering	168377/8375030	9/15/2016	9/15/2018
OMEGA WT4401-D	Omega WT4401-D	Omega Engineering	101105	9/15/2016	9/15/2018

Notes about this calibration

Calibration Result Calibration Successful
 Who Calibrated Kevin Cole

Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.

INSTRUMENT CALIBRATION REPORT



Pine Environmental Services LLC

798 Cromwell Park Dr.
Suite R & S
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID R20401
Description TSI 7575 Q-Trak
Calibrated 5/28/2019 12:35:31PM

Manufacturer Tsi
Model Number 7575
Serial Number/ Lot Number 7575X1130009
Location Maryland
Department

State Certified
Status Pass
Temp °C 22
Humidity % 53

Calibration Specifications

Group # 1
Group Name Functional Test
Test Performed: Yes **As Found Result:** Pass **As Left Result:** Pass

Test Instruments Used During the Calibration

<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>(As Of Cal Entry Date)</u>	
					<u>Last Cal Date/ Opened Date</u>	<u>Next Cal Date / Expiration Date</u>

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Ryan Armstrong

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment
Please call 800-301-9663 for Technical Assistance