

Radon Test Report

November 22, 2023

Batch #: 111623-1

Customer:

ATI Inc.
9220 Rumsey Road
Ste.100
Columbia MD 21045

Test Site:

Avalon ES
7302 Webster Lane
Fort Washington MD

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDJ606		SST	Room 159	10-Nov-2023 12:00 PM	13-Nov-2023 6:23 AM	0.7
SDQ590		SST	Room 142	10-Nov-2023 12:02 PM	13-Nov-2023 6:17 AM	0.2
SKP382		SST	Room 137	10-Nov-2023 12:10 PM	13-Nov-2023 6:21 AM	0.4
SLS325		SST	Room 136	10-Nov-2023 12:08 PM	13-Nov-2023 6:20 AM	0.4
SMA763		SST	Room 161	10-Nov-2023 12:23 PM	13-Nov-2023 6:25 AM	0.5
SMA769		SST	Room 169	10-Nov-2023 12:26 PM	13-Nov-2023 6:26 AM	0.5
SMA841		SST	Room 142	10-Nov-2023 12:02 PM	13-Nov-2023 6:17 AM	0.2
SMA849		SST	Room 177	10-Nov-2023 12:28 PM	13-Nov-2023 6:30 AM	0.4
SMA943		SST	Room 227	10-Nov-2023 12:30 PM	13-Nov-2023 6:32 AM	0.5
SMA981		SST	Room 179	10-Nov-2023 12:30 PM	13-Nov-2023 6:31 AM	0.4
SMP191		SST	Room 145	10-Nov-2023 12:05 PM	13-Nov-2023 6:48 AM	0.7
SMT501		SST	Room 152	10-Nov-2023 12:18 PM	13-Nov-2023 6:22 AM	0.3
SMT881		SST	Room 158	10-Nov-2023 12:21 PM	13-Nov-2023 6:25 AM	1.3
SMV753		SST	Room 139	10-Nov-2023 12:34 PM	13-Nov-2023 6:16 AM	0.7
SMZ435		SST	Room 163	10-Nov-2023 12:25 PM	13-Nov-2023 6:27 AM	0.6

Deployed By:

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125 **Reader Calibration Due:** 8/2/2024

Conditions: Closed-Building Conditions Not Met

Mitigation: Unknown

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: Kimberly Cage **Date:** 22-Nov-2023