

# Radon Test Report

November 22, 2023

Batch #: 111623-5

**Customer:**

ATI Inc.  
9220 Rumsey Road  
Ste.100  
Columbia MD 21045

**Test Site:**

Parkdale H.S.  
6001 Good Luck Road  
Riverdale Park MD 20737

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

**The Results are as follows:**

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDD577		SST	Room 148	10-Nov-2023 12:00 PM	13-Nov-2023 6:21 AM	0.4
SDG767		SST	Room 147	10-Nov-2023 12:58 PM	13-Nov-2023 6:26 AM	0.6
SDG782		SST	Room 137	10-Nov-2023 12:07 PM	13-Nov-2023 6:24 AM	0.6
SDJ584		SST	Room 106	10-Nov-2023 11:38 AM	13-Nov-2023 6:14 AM	0.4
SDM418		SST	Room 101	10-Nov-2023 11:32 AM	13-Nov-2023 6:12 AM	1.1
SDM422		SST	Room 136	10-Nov-2023 12:48 PM	13-Nov-2023 6:24 AM	0.8
SDP252		SST	Room 141	10-Nov-2023 12:55 PM	13-Nov-2023 6:25 AM	0.2
SDW155		SST	Room 8	10-Nov-2023 12:19 PM	13-Nov-2023 6:30 AM	1.5
SGZ613		SST	Room 124	10-Nov-2023 11:53 AM	13-Nov-2023 6:19 AM	0.4
SHH230		SST	Room 103	10-Nov-2023 11:33 AM	13-Nov-2023 6:13 AM	0.6
SHH388		SST	Room 104	10-Nov-2023 11:35 AM	13-Nov-2023 6:13 AM	0.6
SJC602		SST	Room 122	10-Nov-2023 12:57 PM	13-Nov-2023 6:21 AM	1.0
SJX157		SST	Room 118	10-Nov-2023 11:51 AM	13-Nov-2023 6:18 AM	0.6
SKA435		SST	Room 115	10-Nov-2023 11:46 AM	13-Nov-2023 6:18 AM	0.6
SKP607		SST	Room 149	10-Nov-2023 11:58 AM	13-Nov-2023 6:19 AM	0.8
SLD013		SST	Room 135	10-Nov-2023 12:10 PM	13-Nov-2023 6:24 AM	0.4
SLF559		SST	Room 133 Preparation Rm.	10-Nov-2023 12:15 PM	13-Nov-2023 6:23 AM	0.5
SLH678		SST	Room 113	10-Nov-2023 11:45 AM	13-Nov-2023 6:18 AM	0.8
SLJ831		SST	Room 133	10-Nov-2023 12:12 PM	13-Nov-2023 6:23 AM	0.8
SLK531		SST	Room116	10-Nov-2023 11:48 AM	13-Nov-2023 6:18 AM	0.4
SLY559		SST	Room 107	10-Nov-2023 11:40 AM	13-Nov-2023 6:15 AM	0.4
SLY822		SST	Room 5	10-Nov-2023 12:26 PM	13-Nov-2023 6:37 AM	0.5
SMA806		SST	Room 109	10-Nov-2023 12:45 PM	13-Nov-2023 6:18 AM	0.3
SMA873		SST	Room 111	10-Nov-2023 11:42 AM	13-Nov-2023 6:15 AM	0.5
SMA924		SST	Room 132	10-Nov-2023 12:12 PM	13-Nov-2023 6:26 AM	0.4
SMF481		SST	Room 131	10-Nov-2023 12:17 PM	13-Nov-2023 6:22 AM	0.7
SMU381		SST	Room 105	10-Nov-2023 11:37 AM	13-Nov-2023 6:14 AM	0.2
SMU490		SST	Room 142	10-Nov-2023 12:53 PM	13-Nov-2023 6:26 AM	0.7
SMY731		SST	Room 134	10-Nov-2023 12:46 PM	13-Nov-2023 6:28 AM	0.5
SMZ068		SST	Room 146	10-Nov-2023 12:01 PM	13-Nov-2023 6:30 AM	1.0
SMZ513		SST	Room 143	10-Nov-2023 12:51 PM	13-Nov-2023 6:31 AM	0.5
SNA081		SST	Room 145	10-Nov-2023 12:03 PM	13-Nov-2023 6:33 AM	0.3
SNB310		SST	Room138	10-Nov-2023 12:06 PM	13-Nov-2023 6:32 AM	0.9
SNB768		SST	Room 140	10-Nov-2023 12:50 PM	13-Nov-2023 6:33 AM	0.4
SNL730		SST	Guidance Office	10-Nov-2023 12:23 PM	13-Nov-2023 6:35 AM	0.9

**Deployed By:**

**Retrieved By:**

**Analyzed By:** Kimberly Cage 20SS034

**Reader S/N:** E0125

**Reader Calibration Due:** 8/2/2024

# Radon Test Report

November 22, 2023

Batch #: 111623-5

**Customer:**

ATI Inc.  
9220 Rumsey Road  
Ste.100  
Columbia MD 21045

**Test Site:**

Parkdale H.S.  
6001 Good Luck Road  
Riverdale Park MD 20737

---

**Conditions:** Closed-Building Conditions Not Met

**Mitigation:** Unknown

---

## Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ *Kimberly Cage*

Date: \_\_\_\_\_ *29-Nov-2023*